












FACADE 1



FACADE 2




FACADE 3



FACADE 4

 Ranuntie 224 FIN 93101 Pudasjärvi Tel +358(0)20 770 7400 Fax +358(0)20 770 7516	H16538	Master plan	3
		DRAWING	
Novelinda LLC Children House Russia		Facade	1:100
B.Sc.(Eng.) Lehmikangas Antti Planner,	23.1.2015	Model GL 275x275 T Doc.num. H16538 - 1440528 - 04	

Midline of logs






AP6_APT6

Inside	Finish floor level	The top of slab
	+0.201	-0.000
Terrace		
	+0.178	-0.050

CHECKING LIST - FOUNDATION

1. The lowest assembly level of logs - Final ground surface level $\approx$ 300 mm	ok
2. Horizontal measurements, crosswise measurement - Main measures Tolerance: - 5 mm, +10 mm Look at drawin No: 4	
3. Height level - Tolerance - 5 mm, +- 0.000	
4. The lowest assembly level of logs - Terrace floor level $\approx$ 50 mm Look at Det F3	
5. Anchoring bolt - Location: see drawing number No: 6, 8 - Height level: see details F1-anc, F1-Hilti - Tolerance +- 10 mm	

Foundation measures



 Ranuntie 224 FIN 93101 Pudasjärvi Tel +358(0)20 770 7400 Fax +358(0)20 770 7516	H16538	Foundation DRAWING	4
Novelinda LLC Children House Russia	Midline of logs Measures	1:50 1:50	
B.Sc.(Eng.) Lehmikangas Antti Planner.	27.12.2015	Model GL 275x275 T Doc.num. H16538 - 1440528 - 04	